

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Annual Periodical Renewal Fire Certificate

From:
District Fire Officer
Andhra Pradesh, Krishna

To:
The District Educational Officer,
The District Educational Officer

File No: 11504/KRI/DFO/2020, Date:12/08/2020

Occupancy NoC RC Number: 5152/A2/2013

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **Viswabharati Wisewoods E.M. High School, represented by P.Manjula, R.S.No.173, 174, Vanapamula Village, Pedaparupudi Mandal** - Regarding.

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 5152/A2/2013, Dt.02/02/2017
 4. Renewal NOC For Occupancy 5152/A2/2013, Dt.20/03/2019
 5. Online Application for Renewal NOC of P.Manjula, R.S.No.173, 174, Vanapamula Village, Pedaparupudi Mandal - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 06-08-2020.

<< 0 >>

The Management of Viswabharati Wisewoods E.M. High School, represented by P.Manjula, R.S.No.173, 174, Vanapamula Village, Pedaparupudi Mandal has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.405523/- vide challan No. 31302788622019, Dated 18/01/2020 at Online, Online.

Hostle Block - I

,Hostle Block - IV

,Educational Block

,Other Block

,Hostle Block - II

,Hostle Block - III

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.


PRINCIPAL
Viswabharathi Wisewoods (E.M.) High School,
VANAPAMULA - 521 263, Krishna Dist. (A.P.)

2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **P.Manjula R.S.No.173, 174, Vanapamula Village, Pedaparupudi Mandal**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 02/02/2020 to 01/02/2025.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.
- The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

The renewal to No Objection Certificate for Occupancy is issued subject to the condition that the management has to maintain all the Fire Precautionary and Fire Preventive measures as per No Objection Certificate for Occupancy. Further as per G.O.Ms No. 169, Home (Prisons & Fire) Department Dated, 19-12-2019 the management has to submit declaration every year in prescribed format as furnished by Fire Service Department that Fire Prevention and Fire Safety Measures provided are being maintained in good and efficient condition, in accordance with Act and Rules.



11504/KRI/DF0/2020

Your Sincerely,

District Fire Officer
Andhra Pradesh, Krishna

2/3